

CERTIFICATE OF COMPLIANCE

Certificate Number MH6497
Report Reference MH6497-20040303
Issue Date 2020-JULY-06

Issued to: VEEDER-ROOT CO
2709 ROUTE 764
DUNCANSVILLE, PA 16635-8047 USA

This is to certify that representative samples of PUMPS, POWER OPERATED, FLAMMABLE LIQUID
(See Addendum for Additional Information.)

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: (See Addendum for Standards for Safety.)
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number MH6497
Report Reference MH6497-20040303
Issue Date 2020-JULY-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL - Model designations: P, PC, PL, or PV with or without Prefix X3 or X4, followed by 33, 75, 150, or 200, followed by R, S, or U, followed by 1, 3, 17, or 20, with or without -2, -3 or -4, followed by RJX or RAX where X is a number representing a variable length range not to exceed 19 feet, or RJXXXX or RAXXXX where XXXX is a 4 digit number representing length. All Models have been evaluated for use with gasoline-ethanol blends with concentrations from E0-E10. Basic Model No. P200U20 is only for use with Model VSFC variable speed flow controller drive.

USL - Model designations: P or PL with or without Prefix X3 or X4, with Prefix AG followed by 33, 75, or 150, followed by R or S, followed by 1, 3, or 17, with or without -2, -3 or -4, followed by RJX where X is a number representing a variable length range not to exceed 19 feet, or RJXXXX where XXXX is only 4 digit number representing length. All Models have been evaluated for use with gasoline-ethanol blends with concentrations from 0 to 85 percent ethanol or 0 to 15 percent methanol, biodiesel (B100), diesel/biodiesel blends with nominal biodiesel concentrations up to 20 percent (B20).

Standards for Safety:

ANSI/UL 79, "Power-Operated Pumps for Petroleum Dispensing Products" — For products intended for use with gasoline or gasoline/ethanol blends with nominal ethanol concentrations up to 10 percent (gasohol, E10), diesel fuel, diesel/biodiesel blends with nominal biodiesel concentrations up to 5 percent (B5), kerosene, or fuel oil.

ANSI/UL 79A, "Power-Operated Pumps for Gasoline and Gasoline/Ethanol Blends with Nominal Ethanol Concentrations up to 85 Percent (E0 - E85)" — For products intended for use with gasoline or gasoline/ethanol blends with nominal ethanol concentrations up to 85 percent (E85).

ANSI/UL 79B, "Power-Operated Pumps for Diesel Fuel, Biodiesel Fuel, Diesel/Biodiesel Blends with Nominal Biodiesel Concentrations up to 20 Percent (B20), Kerosene, and Fuel Oil" — For products intended for use with diesel fuel, biodiesel fuel, diesel/biodiesel blends with nominal biodiesel concentrations up to 20 percent (B20), kerosene or fuel oil.

UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations.

CAN/CSA C22.2 No. 4 – Bonding and Grounding of Electrical Equipment.

CAN/CSA C22.2 No. 5 – Threaded Conduit Entries.

CAN/CSA C22.2 No. 22 – Electrical Equipment for Flammable Liquid Dispensers.

CAN/CSA C22.2 No. 30 – Explosion Proof Enclosures for Use in Class I Hazardous Locations.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

